



CAUTION:
 CONTACT UTILITY COMPANIES AND
 USA PRIOR TO ANY SITE EXCAVATION
 AND TRACE TO LOCATE, PROTECT, AND
 PRESERVE ALL EXISTING UNDERGROUND
 FACILITIES.

UTILITY COMPANY REQUIREMENTS
 VERIFY AND COMPLY WITH ALL UTILITY COMPANY REQUIREMENTS
 BEFORE BIDDING, JOB AND OBTAIN ENGINEERED DOCUMENTS
 BEFORE CONSTRUCTION.

POWER CO STEVEN JONES PH (559) 675-2258
 TELEPHONE CO MARTA OLIVO PH (559) 454-3041
 CATV CO FRANK CASTRO PH (209) 395-5052
 CONCAST

KEYNOTES

- ONE 4" C.O. (PDATE PRIMARY) PER PAGE RULES AND REGULATIONS.
- N/99 4" E TRANSFORMER, RISE/RISE AND INSTALL TRANSFORMER PAD AND GROUNDING FACILITIES PER PAGE RULES AND REGULATIONS.
- FOUR 5" C.O. (PDATE SECONDARY) PER PAGE RULES AND REGULATIONS.
- ONE 1" C. - 2" #12 + 1" #12 GND (C/THIN) FOR GENERATOR BATTERY CHARGER, AND ONE 1" C. - 2" #12 + 1" #12 GND (C/THIN) FOR COOLANT HEATER PER SINGLE LINE DIAGRAM #1/E/200.
- THO 3" C.O.'S 1 CONDUCTORS (GENERATOR FEEDER), ONE 1" C. + CONTROL, SINGING TRANSFER SWITCH, AND ONE 1" C. + PULL CORD (SPARE) PER SINGLE LINE DIAGRAM #1/E/200.
- THO 4" C.O.'S FOR N/ HIBER TEL/DATA RAN CONCEALED IN ACCESSIBLE ATTIC THEN DROP DOWN TO (B) TEL/DATA FACILITIES. VERIFY EXACT LOCATION WITH OWNER AT SITE.
- THO 4" C.O.'S FOR N/ HIBER TEL/DATA LEAD THRU WALL FROM ATTIC, DROP DOWN BUILDING EXTERIOR AND CONTINUE AS NOTED. VERIFY EXACT LOCATION WITH OWNER AT SITE AND SEAL EXTERIOR WALL PENETRATION AS REQUIRED.
- THO 4" C.O.'S FOR N/ HIBER TEL/DATA CONNECTION FROM EXISTING FACILITIES LOCATED AT (B) TECH CENTER BY OWNER. VERIFY EXACT ROUTE WITH OWNER AT SITE.
- THO 4" C.O.'S FOR N/ HIBER TEL/DATA CONNECTION FROM EXISTING FACILITIES LOCATED AT (B) TECH CENTER BY OWNER. VERIFY EXACT ROUTE WITH OWNER AT SITE.
- THO 4" C.O.'S FOR FUTURE AT (A) TEL/DATA SERVICE PER TELEPHONE COMPANY REQUIREMENTS, RULES, AND REGULATIONS.
- EXISTING TELEPHONE COMPANY 3" x 5" SERVICE YALTY. VERIFY EXACT LOCATION AT SITE AND COORDINATE INSTALLATION OF N/ CONDUITS WITH A/E AT SITE.
- THO 2" C.O.'S FOR N/ CATV SERVICE PER CATV CO. REQUIREMENTS, RULES AND REGULATIONS.
- N/ 11/4" x 3/4" x 1/8" VOLT PER PER CATV CO. REQUIREMENTS, RULES AND REGULATIONS.
- THO 2" C.O.'S FOR N/ CATV SERVICE. STUB UP AT BASE OF N/ CATV SERVICE RISER POLE PER PER CATV CO. REQUIREMENTS, RULES AND REGULATIONS.
- N/ CATV SERVICE RISE POLE BY CATV COMPANY.
- N/ OVERHEAD CATV SERVICE BY CATV COMPANY.
- N/ CATV SERVICE RISE POLE BY CATV COMPANY. CATV COMPANY TO PROVIDE N/ CATV SERVICE FROM (B) ADVISORY FACILITIES. ONE 1" C. WITH PULL CORD FROM LIGHT POLE TO USE IN DPEL/ELC ROOM FOR SECONDARY VIDEO CAMERA (OWNERS BY OWNER).

GENERAL NOTES

- VERIFY EXACT PUBLIC UTILITY EASEMENT AND/OR RIGHT OF WAY WITH RESPECTIVE UTILITY COMPANIES PRIOR TO PLACEMENT OF CONDUIT, SUB-STRUCTURES, ETC.

